

**CHECKLIST FOR FIRE DEPARTMENT REQUIREMENTS  
REGARDING FOOD VENDORS  
RIDGEMOUNT SUMMER FESTIVAL 2019**



1. All food carts with commercial cooking will provide at least one 40BC or a "K" class portable fire extinguisher. This extinguisher have been serviced by a qualified technician tagged and sealed within the year  
 40BC or "K" Class extinguisher provided   
 Service date within October 2018 to October 2019 \_\_\_\_\_
  
2. A ventilation hood is in place above the cooking appliances and meets the intent of NFPA 96, 2011 Edition.  
 Hood is in place   
 Hood is clean and free of grease
  
3. A certified fixed extinguishing system is in place in accordance with ULC 1254.6 or UL 300 standards for commercial cooking.  
*A qualified technician has certified this system within 6 months prior to the festival.*  
 Fixed extinguishing system is in place – meeting standards above   
 Service date within April 2019 to October 2019 \_\_\_\_\_   
 A copy of the technician's paperwork is in the food cart
  
4. Barbecues and other outdoor cooking appliances shall be **located outside the tent envelope**. Note: if sufficient clearance and ventilation can be obtained, the Inspector will have final approval for appliances within the fire-rated tent structure.  
  
*A minimum of one 2A:10BC portable fire extinguisher will be provide and serviced as per Item 1.*  
 Inspector approval for interior tent use \_\_\_\_\_   
 Appliance outside the tent structure   
 Fire-rated tent (accordance with OBC or equivalent)   
 2A:10BC extinguisher or greater provided   
 Service date within October 2018 to October 2019 \_\_\_\_\_
  
5. All other food carts (non-grease laden vapours) shall provide a minimum of one 2A:10BC portable fire extinguisher.  
*The extinguisher will be serviced as per Item 1.*  
 2A:10BC extinguisher or greater provided   
 Service date within October 2018 to October 2019 \_\_\_\_\_
  
6. Ovens will not require a fixed extinguishing system and ventilation hood if no grease-laden vapours are produced.  
 Ovens will be allowed under fire-rated tents (OBC certified or equivalent) with sufficient clearance.  
*A minimum of one 2A:10BC portable fire extinguisher will be provide and serviced as per Item 1.*  
 Fire-rated tent (accordance with OBC or equivalent)   
 Sufficient clearance   
 2A:10BC extinguisher or greater provided   
 Service date within October 2018 to October 2019 \_\_\_\_\_
  
7. Propane installations to meet all TSSA regulation and have a current Mobile Food Services certificate.  
*TSSA will be on site conducting inspection prior to opening day*  
 Propane tanks are secure.   
 TSSA Mobile Food Services Inspection   
 Approved Appliances